

- (b) The fuel line shall be—
 - (1) Capable of withstanding working pressures and stresses;
 - (2) Located to prevent damage; and
 - (3) Located in areas free of combustible materials or in areas where any exposed combustible materials are coated with one inch of shotcrete, one-half inch of gunite, or other non-combustible material with equivalent fire protection characteristics.
- (c) Provisions shall be made for control or containment of the entire volume of the fuel line so that leakage will not create a fire hazard.

§57.4530 Exits for surface buildings and structures.

Surface buildings or structures in which persons work shall have a sufficient number of exits to permit prompt escape in case of fire.

§57.4531 Surface flammable or combustible liquid storage buildings or rooms.

- (a) Surface storage buildings or storage rooms in which flammable or combustible liquids, including grease, are stored and that are within 100 feet of any person's work station shall be ventilated with a sufficient volume of air to prevent the accumulation of flammable vapors.
- (b) In addition, the buildings or rooms shall be—
 - (1) Constructed to meet a fire resistance rating of at least one hour; or
 - (2) Equipped with an automatic fire suppression system; or
 - (3) Equipped with an early warning fire detection device that will alert any person who could be endangered by a fire, provided that no person's work station is in the building.
- (c) Flammable or combustible liquids in use for day-to-day maintenance and operational activities are not considered in storage under this standard.

§57.4532 Blacksmith shops.

- Blacksmith shops located on the surface shall be—
 - (a) At least 100 feet from fan installations used for intake air and mine openings;
 - (b) Equipped with exhaust vents over the forge and ventilated to prevent the

- accumulation of the products of combustion; and
- (c) Inspected for smoldering fires at the end of each shift.

§57.4533 Mine opening vicinity.

- Surface buildings or other similar structures within 100 feet of mine openings used for intake air or within 100 feet of mine openings that are designated escapeways in exhaust air shall be—
 - (a) Constructed of noncombustible materials; or
 - (b) Constructed to meet a fire resistance rating of no less than one hour; or
 - (c) Provided with an automatic fire suppression system; or
 - (d) Covered on all combustible interior and exterior structural surfaces with noncombustible material or limited combustible material, such as five-eighth inch, type "X" gypsum wall-board.

§57.4560 Mine entrances.

- For at least 200 feet inside the mine portal or collar timber used for ground support in intake openings and in exhaust openings that are designated as escapeways shall be—
 - (a) Provided with a fire suppression system, other than fire extinguishers and water hoses, capable of controlling a fire in its early stages; or
 - (b) Covered with shotcrete, gunite, or other material with equivalent fire protection characteristics; or
 - (c) Coated with fire-retardant paint or other material to reduce its flame spread rating to 25 or less and maintained in that condition.

[50 FR 4082, Jan. 29, 1985, as amended at 50 FR 20100, May 14, 1985]

§57.4561 Stationary diesel equipment underground.

- Stationary diesel equipment underground shall be—
 - (a) Supported on a noncombustible base; and
 - (b) Provided with a thermal sensor that automatically stops the engine if overheating occurs.