

§ 35.927

shall be performed. When the VE analysis is completed, a preliminary report summarizing the VE findings and a final report describing implementation of the VE recommendations must be submitted to the project officer on a schedule approved by him.

(c) *Implementation.* For those projects for which a VE analysis has been performed in accordance with paragraph (b) of this section, VE recommendations shall be implemented to the maximum extent feasible, as determined by the grantee, subject to the approval of the EPA project officer. Rejection of any recommendation shall be on the basis of cost-effectiveness, reliability, extent of project delays, and other factors that may be critical to the treatment processes and the environmental impact of the project.

§ 35.927 Sewer system evaluation and rehabilitation.

(a) All applicants for step 2 or step 3 grant assistance must demonstrate to the Regional Administrator's satisfaction that each sewer system discharging into the treatment works project for which grant application is made is not or will not be subject to excessive infiltration/inflow. A determination of whether excessive infiltration/inflow exists may take into account, in addition to flow and related data, other significant factors such as cost-effectiveness (including the cost of substantial treatment works construction delay, see appendix A to this subpart), public health emergencies, the effects of plant bypassing or overloading, or relevant economic or environmental factors.

(b) A sewer system evaluation will generally be used to determine whether or not excessive infiltration/inflow exists. It will consist of:

- (1) Certification by the State agency, as appropriate; and, when necessary,
- (2) An infiltration/inflow analysis; and, if appropriate,
- (3) A sewer system evaluation survey and, if appropriate, a program, including an estimate of costs, for rehabilitation of the sewer system to eliminate excessive infiltration/inflow identified in the sewer system evaluation. Information submitted to the Regional Administrator for such determination

should be the minimum necessary to enable him to make a judgment.

(c) Guidelines on sewer system evaluation published by the Administrator provide further advisory information (see § 35.900(c)). Also see §§ 35.925-7(c) and 35.935-16.

§ 35.927-1 Infiltration/inflow analysis.

(a) The infiltration/inflow analysis shall demonstrate the nonexistence or possible existence of excessive infiltration/inflow in the sewer system. The analysis should identify the presence, flow rate, and type of infiltration/inflow conditions which exist in the sewer system.

(b) For determination of the possible existence of excessive infiltration/inflow, the analysis shall include an estimate of the cost of eliminating the infiltration/inflow conditions. These costs shall be compared with estimated total costs for transportation and treatment of the infiltration/inflow. Cost-effectiveness analysis guidelines (Appendix A to this subpart) should be consulted with respect to this determination.

(c) If the infiltration/inflow analysis demonstrates the existence or possible existence of excessive infiltration/inflow a detailed plan for a sewer system evaluation survey shall be included in the analysis. The plan shall outline the tasks to be performed in the survey and their estimated costs.

§ 35.927-2 Sewer system evaluation survey.

(a) The sewer system evaluation survey shall identify the location, estimated flow rate, method of rehabilitation and cost of rehabilitation versus cost of transportation and treatment for each defined source of infiltration/inflow.

(b) A report shall summarize the results of the sewer system evaluation survey. In addition, the report shall include:

- (1) A justification for each sewer section cleaned and internally inspected.
- (2) A proposed rehabilitation program for the sewer system to eliminate all defined excessive infiltration/inflow.