

§ 428.114

§ 428.114 [Reserved]

§ 428.115 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent limitations		
Effluent characteristic	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Zinc	0.058	0.024
BOD ₅	2.4	1.4
TSS	2.26	0.94
pH	(¹)	(¹)
English units (lb/1,000 lb of raw material)		
Zinc	0.058	0.024
BOD ₅	2.4	1.4
TSS	2.26	0.94
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

§ 428.116 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged to a publicly owned treatment works by a new point source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standards	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kg/kg of raw material)		
Zinc	0.058	0.024
BOD ₅	(¹)	(¹)
TSS	(¹)	(¹)
pH	(¹)	(¹)
English units (lb/1,000 lb of raw material)		
Zinc	0.058	0.024
BOD ₅	(¹)	(¹)
TSS	(¹)	(¹)
pH	(¹)	(¹)

¹ No limitation.

[40 FR 2345, Jan. 10, 1975, as amended at 60 FR 33964, June 29, 1995]

PART 429—TIMBER PRODUCTS PROCESSING POINT SOURCE CATEGORY

GENERAL PROVISIONS

- Sec.
- 429.10 Applicability.
- 429.11 General definitions.
- 429.12 Monitoring requirements. [Reserved]

Subpart A—Barking Subcategory

- 429.20 Applicability; description of the barking subcategory.
- 429.21 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).
- 429.22 Effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT). [Reserved]
- 429.23 Effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT). [Reserved]
- 429.24 New source performance standards (NSPS).
- 429.25 Pretreatment standards for existing sources (PSES).
- 429.26 Pretreatment standards for new sources (PSNS).

Subpart B—Veneer Subcategory

- 429.30 Applicability; description of the veneer subcategory.