

**Environmental Protection Agency**

**§ 63.420**

- (ii) Certify that source has complied with § 63.402 of this subpart; and
- (iii) Include the information required in paragraph (a)(1)(iv) of this section.
- (iv) Include the following statement:

I certify that no chromium-based water treatment chemicals have been introduced since (the initial compliance date) into any IPCT located within the facility for any purpose.

**§ 63.406 Recordkeeping and reporting requirements.**

To demonstrate continuing compliance with § 63.402 of this subpart, the owner or operator of each affected IPCT shall maintain copies of the initial notification and the notification of compliance status as required by § 63.405 of this subpart for a period of at least 5 years onsite.

TABLE 1 TO SUBPART Q—GENERAL PROVISIONS APPLICABILITY TO SUBPART Q

Reference	Applies to Subpart Q	Comment
63.1 .....	Yes.	
63.2 .....	Yes.	
63.3 .....	No.	
63.4 .....	Yes.	
63.5 .....	No.	
63.6 (a), (b), (c), and (j) .....	Yes.	
63.6 (d), (e), (f), (g), (h), and (i) .....	No.	
63.7 .....	No.	
63.8 .....	No.	
63.9 (a), (b)(1), (b)(3), (c), (h)(1), (h)(3), (h)(6), and (j) .....	Yes.	
63.9 (b)(2), (b)(4), (b)(5), (b)(6), (d), (e), (f), (g), (h)(2), (h)(4), (h)(5) .....	No .....	Requirements for initial notifications and notifications of compliance status are specified in § 63.405(a) and § 63.405(b), respectively, of subpart Q; other provisions of subpart A are not relevant to IPCT's.
63.10 (a), (b)(1), (b)(2)(xii), (b)(2)(xiv), (b)(3), (d), and (f) .....	Yes .....	Section 63.406 requires an onsite record retention of 5 years.
63.10 (b)(2) (i) to (xi), (c), and (e) .....	No.	
63.11 .....	No.	
63.12 to 63.15 .....	Yes.	

**Subpart R—National Emission Standards for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations)**

SOURCE: 59 FR 64318, Dec. 14, 1994, unless otherwise noted.

**§ 63.420 Applicability.**

(a) The affected source to which the provisions of this subpart apply is each bulk gasoline terminal, except those bulk gasoline terminals:

(1) For which the owner or operator has documented and recorded to the Administrator's satisfaction that the result,  $E_T$ , of the following equation is less than 1, and complies with requirements in paragraphs (c), (d), (e), and (f) of this section:

$$E_T = CF [0.59(T_F)(1 - CE) + 0.17(T_E) + 0.08(T_{ES}) + 0.038(T_I) + 8.5 \times 10^{-6}(C) + KQ] + 0.04(OE)$$

where:

- $E_T$  = emissions screening factor for bulk gasoline terminals;
- $CF=0.161$  for bulk gasoline terminals and pipeline breakout stations that do not handle any reformulated or oxygenated gasoline containing 7.6 percent by volume or greater methyl tert-butyl ether (MTBE), OR  $CF=1.0$  for bulk gasoline terminals and pipeline breakout stations that handle reformulated or oxygenated gasoline containing 7.6 percent by volume or greater MTBE;
- $CE$ =control efficiency limitation on potential to emit for the vapor processing system used to control emissions from fixed-roof gasoline storage vessels [value should be added in decimal form (percent divided by 100)];
- $T_F$  = total number of fixed-roof gasoline storage vessels without an internal floating roof;
- $T_E$  = total number of external floating roof gasoline storage vessels with only primary seals;