

Environmental Protection Agency

§ 68.83

be informed of, and trained in, the change prior to start-up of the process or affected part of the process.

(d) If a change covered by this paragraph results in a change in the process safety information required by § 68.65 of this part, such information shall be updated accordingly.

(e) If a change covered by this paragraph results in a change in the operating procedures or practices required by § 68.69, such procedures or practices shall be updated accordingly.

§ 68.77 Pre-startup review.

(a) The owner or operator shall perform a pre-startup safety review for new stationary sources and for modified stationary sources when the modification is significant enough to require a change in the process safety information.

(b) The pre-startup safety review shall confirm that prior to the introduction of regulated substances to a process:

(1) Construction and equipment is in accordance with design specifications;

(2) Safety, operating, maintenance, and emergency procedures are in place and are adequate;

(3) For new stationary sources, a process hazard analysis has been performed and recommendations have been resolved or implemented before startup; and modified stationary sources meet the requirements contained in management of change, § 68.75.

(4) Training of each employee involved in operating a process has been completed.

§ 68.79 Compliance audits.

(a) The owner or operator shall certify that they have evaluated compliance with the provisions of this subpart at least every three years to verify that procedures and practices developed under this subpart are adequate and are being followed.

(b) The compliance audit shall be conducted by at least one person knowledgeable in the process.

(c) A report of the findings of the audit shall be developed.

(d) The owner or operator shall promptly determine and document an appropriate response to each of the

findings of the compliance audit, and document that deficiencies have been corrected.

(e) The owner or operator shall retain the two (2) most recent compliance audit reports.

[61 FR 31722, June 20, 1996, as amended at 64 FR 979, Jan. 6, 1999]

§ 68.81 Incident investigation.

(a) The owner or operator shall investigate each incident which resulted in, or could reasonably have resulted in a catastrophic release of a regulated substance.

(b) An incident investigation shall be initiated as promptly as possible, but not later than 48 hours following the incident.

(c) An incident investigation team shall be established and consist of at least one person knowledgeable in the process involved, including a contract employee if the incident involved work of the contractor, and other persons with appropriate knowledge and experience to thoroughly investigate and analyze the incident.

(d) A report shall be prepared at the conclusion of the investigation which includes at a minimum:

(1) Date of incident;

(2) Date investigation began;

(3) A description of the incident;

(4) The factors that contributed to the incident; and,

(5) Any recommendations resulting from the investigation.

(e) The owner or operator shall establish a system to promptly address and resolve the incident report findings and recommendations. Resolutions and corrective actions shall be documented.

(f) The report shall be reviewed with all affected personnel whose job tasks are relevant to the incident findings including contract employees where applicable.

(g) Incident investigation reports shall be retained for five years.

§ 68.83 Employee participation.

(a) The owner or operator shall develop a written plan of action regarding the implementation of the employee participation required by this section.

§ 68.85

(b) The owner or operator shall consult with employees and their representatives on the conduct and development of process hazards analyses and on the development of the other elements of process safety management in this rule.

(c) The owner or operator shall provide to employees and their representatives access to process hazard analyses and to all other information required to be developed under this rule.

§ 68.85 Hot work permit.

(a) The owner or operator shall issue a hot work permit for hot work operations conducted on or near a covered process.

(b) The permit shall document that the fire prevention and protection requirements in 29 CFR 1910.252(a) have been implemented prior to beginning the hot work operations; it shall indicate the date(s) authorized for hot work; and identify the object on which hot work is to be performed. The permit shall be kept on file until completion of the hot work operations.

§ 68.87 Contractors.

(a) *Application.* This section applies to contractors performing maintenance or repair, turnaround, major renovation, or specialty work on or adjacent to a covered process. It does not apply to contractors providing incidental services which do not influence process safety, such as janitorial work, food and drink services, laundry, delivery or other supply services.

(b) *Owner or operator responsibilities.*

(1) The owner or operator, when selecting a contractor, shall obtain and evaluate information regarding the contract owner or operator's safety performance and programs.

(2) The owner or operator shall inform contract owner or operator of the known potential fire, explosion, or toxic release hazards related to the contractor's work and the process.

(3) The owner or operator shall explain to the contract owner or operator the applicable provisions of subpart E of this part.

(4) The owner or operator shall develop and implement safe work practices consistent with § 68.69(d), to control the entrance, presence, and exit of

40 CFR Ch. I (7-1-00 Edition)

the contract owner or operator and contract employees in covered process areas.

(5) The owner or operator shall periodically evaluate the performance of the contract owner or operator in fulfilling their obligations as specified in paragraph (c) of this section.

(c) *Contract owner or operator responsibilities.* (1) The contract owner or operator shall assure that each contract employee is trained in the work practices necessary to safely perform his/her job.

(2) The contract owner or operator shall assure that each contract employee is instructed in the known potential fire, explosion, or toxic release hazards related to his/her job and the process, and the applicable provisions of the emergency action plan.

(3) The contract owner or operator shall document that each contract employee has received and understood the training required by this section. The contract owner or operator shall prepare a record which contains the identity of the contract employee, the date of training, and the means used to verify that the employee understood the training.

(4) The contract owner or operator shall assure that each contract employee follows the safety rules of the stationary source including the safe work practices required by § 68.69(d).

(5) The contract owner or operator shall advise the owner or operator of any unique hazards presented by the contract owner or operator's work, or of any hazards found by the contract owner or operator's work.

Subpart E—Emergency Response

SOURCE: 61 FR 31725, June 20, 1996, unless otherwise noted.

§ 68.90 Applicability.

(a) Except as provided in paragraph (b) of this section, the owner or operator of a stationary source with Program 2 and Program 3 processes shall comply with the requirements of § 68.95.

(b) The owner or operator of stationary source whose employees will not respond to accidental releases of regulated substances need not comply