

(c) An enclosed space that has direct access to a Division 2 location is not a hazardous location if—

(1) The access has a self-closing, gas-tight door that opens into the space and that has no hold-back device;

(2) Ventilation causes the air to flow with the door open from the space into the Division 2 location; and

(3) Loss of ventilation activates an alarm at a manned control station.

**§ 108.177 Electrical equipment in classified locations.**

Electrical equipment and devices installed in spaces made non-hazardous by the methods indicated in §108.175 must only be essential equipment.

VENTILATION

**§ 108.181 Ventilation for enclosed spaces.**

(a) Each enclosed space must be vented or ventilated.

(b) There must be a means to close each vent or ventilating system.

(c) Each fan in a ventilating system must have remote controls installed in accordance with part 111, subpart 111.103, of this chapter.

(d) There must be a means to close each doorway, ventilator, and annular space around each funnel or other opening to machinery, stowage, or working spaces. The means must be located outside the space.

(e) Each intake in a ventilating system must be located so as to prevent, as far as practicable, the intake of noxious fumes.

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 94-108, 61 FR 28270, June 4, 1996]

**§ 108.185 Ventilation for enclosed classified locations.**

(a) The ventilation system for each enclosed classified location must be designed to maintain a pressure differential between the enclosed classified location and each non-classified location adjacent to the enclosed classified location, so as to prevent the discharge of ignitable gases into the non-classified adjacent locations.

(b) Each air intake must be outside of enclosed classified locations.

(c) Each unit must have alarms that are powered independently of the ventilation motor power and control circuitry and sound at a continuously manned station when—

(1) Gas is present in an enclosed classified location; or

(2) The ventilation system for the space is not working.

(d) Each ventilation system for enclosed classified locations must provide a complete change of air every five minutes.

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 94-108, 61 FR 28270, June 4, 1996]

**§ 108.187 Ventilation for brush type electric motors in classified spaces.**

Ventilation for brush type electric motors in classified locations must meet N.F.P.A. 496-1974 "Standard for Purged and Pressurized Enclosures for Electrical Equipment in Hazardous Locations", except audible and visual alarms may be used if shutting down the motors may cause unsafe conditions.

ACCOMMODATION SPACES

**§ 108.193 Restrictions.**

(a) There must be no direct communication between the accommodation spaces and any chainlocker, stowage, or machinery space, except through solid, close-fitted doors or hatches.

(b) No access, vent, or sounding tube from a fuel or oil tank may open into any accommodation space, except that accesses and sounding tubes may open into corridors.

**§ 108.195 Location of accommodation spaces.**

(a) On surface type units, accommodation spaces must not be located forward of a vertical plane located at 5 percent of the unit's length aft of the stem, at the designed summer load line.

(b) On all units, the deckhead of each accommodation space must be above the deepest load line.

**§ 108.197 Construction of accommodation spaces.**

(a) Each sleeping, mess, recreational, or hospital space that is adjacent to or