

Coast Guard, DHS

§ 108.441

(incorporated by reference, see §105.01–3).

(b) A cutoff valve and check valve for each connection; and

(c) Facilities available enabling the connection to be used on either side of the unit.

[CGD 73–251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 88–032, 56 FR 35826, July 29, 1991; USCG–2000–7790, 65 FR 58462, Sept. 29, 2000]

§ 108.429 Fire main system protection.

(a) Each pipe and fire hydrant in a fire main system must be installed to the extent practicable in locations that are not exposed to damage by materials that are moved on or onto the deck.

(b) Each part of the fire main system located on an exposed deck must either be protected against freezing or be fitted with cutout valves and drain valves to shut off and drain the entire exposed system in freezing weather.

AUTOMATIC SPRINKLING SYSTEMS

§ 108.430 General.

Automatic sprinkler systems must comply with Chapter 25 of NFPA 13 (incorporated by reference, see §108.101).

[USCG–2012–0196, 81 FR 48266, July 22, 2016]

FIXED CARBON DIOXIDE FIRE EXTINGUISHING SYSTEMS

§ 108.431 Carbon dioxide systems: General.

(a) Sections 108.431 through 108.457 apply to high pressure carbon dioxide fire extinguishing systems.

(b) Low pressure systems, that is, those in which the carbon dioxide is stored in liquid form at low temperature, must be approved by the Commandant.

(c) Each carbon dioxide system cylinder must be fabricated, tested, and marked in accordance with §§147.60 and 147.65 of this chapter.

[CGD 73–251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 84–044, 53 FR 7749, Mar. 10, 1988]

§ 108.433 Quantity of CO₂: General.

Each CO₂ system must have enough gas to meet the quantity requirements

of §108.439 for the space requiring the greatest amount of CO₂.

§ 108.437 Pipe sizes and discharge rates for enclosed ventilation systems for rotating electrical equipment.

(a) The minimum pipe size for the initial charge must meet table 108.441 and the discharge of the required amount of CO₂ must be completed within 2 minutes.

(b) The minimum pipe size for the delayed discharge must be at least 1.25 centimeters (½ inch) standard pipe.

(c) The pipe used for the initial discharge must not be used for the delayed discharge, except systems having a volume of less than 57 cubic meters (2,000 cubic feet).

§ 108.439 Quantity of CO₂ for protection of spaces.

(a) The number of pounds of CO₂ required to protect a space must be equal to the gross volume of the space divided by the appropriate factor from Table 108.439.

(b) If a machinery space includes a casing, the gross volume of the space may be calculated using the reductions allowed in 46 CFR 95.10–5(e).

(c) If fuel can drain from a space to an adjacent space or if two spaces are not entirely separate, the requirements for both spaces must be used to determine the amount of CO₂ to be provided and the CO₂ system must be arranged to discharge into both spaces simultaneously.

TABLE 108.439—CO₂ Supply Factors

[Gross volume of space in cubic feet]

Over	Not over	Factor
0	500	15
500	1,600	16
1,600	4,500	18
4,500	50,000	20
50,000		22

§ 108.441 Piping and discharge rates for CO₂ systems.

(a) The size of branch lines to spaces protected by a CO₂ system must meet Table 108.441.

(b) Distribution piping within a space must be proportioned from the supply line to give proper distribution to the outlets without throttling.

§ 108.443

(c) The number, type, and location of discharge outlets must distribute the CO₂ uniformly throughout the space.

TABLE 108.441—CO₂ System Pipe Size

CO ₂ supply in system, kilograms (pounds)	Minimum pipe size (inches), millimeters (inches)
45 (100)	12.7 (½).
104 (225)	19.05 (¾).
136 (300)	25.4 (1).
272 (600)	31.75 (1¼).
450 (1,000)	38.10 (1½).
1,110 (2,450)	50.80 (2).
1,130 (2,500)	63.5 (2½).
2,023 (4,450)	76.2 (3).
3,229 (7,100)	88.9 (3½).
4,750 (10,000)	101.6 (4).
6,818 (15,000)	114.3 (4½).

(d) The total area of all discharge outlets must be more than 35 percent and less than 85 percent of the nominal cylinder outlet area or the area of the supply pipe, whichever is smaller. The nominal cylinder outlet area in square centimeters is determined by multiplying the factor 0.0313 by the number of kilograms of CO₂ required. (The nominal cylinder outlet area in square inches is determined by multiplying the factor 0.0022 by the number of pounds of CO₂ required). The nominal cylinder outlet area must not be less than 71 square millimeters (0.110 square inches).

(e) A CO₂ system must discharge at least 85 percent of the required amount within 2 minutes.

§ 108.443 Controls and valves.

(a) At least one control for operating a CO₂ system must be outside the space or spaces that the system protects and in a location that would be accessible if a fire occurred in any space that the system protects. Control valves must not be located in a protected space unless the CO₂ cylinders are also in the protected space.

(b) A CO₂ system that protects more than one space must have a manifold with a stop valve, the normal position of which is closed, that directs the flow of CO₂ to each protected space.

(c) A CO₂ system that protects only one space must have a stop valve installed between the cylinders and the discharge outlets in the system, except on a system that has a CO₂ supply of 136 kilograms (300 pounds) or less.

46 CFR Ch. I (10–1–22 Edition)

(d) At least one of the control stations in a CO₂ system that protects a machinery space must be as near as practicable to one of the main escapes from that space.

(e) All distribution valves and controls must be of an approved type.

(f) Each CO₂ system that has a stop valve must have a remote control that operates only the stop valve and must have a separate remote control for releasing the required amount of CO₂ into the space protected by the system.

(g) Each CO₂ system that does not have a stop valve must be operated by a remote control that releases the required amount of CO₂ into the space protected by the system.

(h) Remote controls to each space must be in an enclosure.

(i) Each system must have a manual control at its cylinders for releasing CO₂ from the cylinders, except that if the system has pilot cylinders, a manual control is not required for other than pilot cylinders.

(j) If gas pressure is used to release CO₂ from a system having more than 2 cylinders, the system must have at least 2 pilot cylinders to release the CO₂ from the remaining cylinders.

(k) If the entrance to a space containing the CO₂ supply or controls of a CO₂ system has a lock, the space must have a key to the lock in a break-glass type box that is next to and visible from the entrance.

§ 108.444 Lockout valves.

(a) A lockout valve must be provided on any carbon dioxide extinguishing system protecting a space over 6,000 cubic feet in volume and installed or altered after July 9, 2013. “Altered” means modified or refurbished beyond the maintenance required by the manufacturer’s design, installation, operation and maintenance manual.

(b) The lockout valve must be a manually operated valve located in the discharge manifold prior to the stop valve or selector valves. When in the closed position, the lockout valve must provide complete isolation of the system from the protected space or spaces, making it impossible for carbon dioxide to discharge in the event of equipment failure during maintenance.