

TABLE 108.495—CARRIAGE OF PORTABLE FIRE EXTINGUISHERS—Continued

Space	Minimum required rating	Quantity and location
Motors and generators of electric propelling machinery that have enclosed ventilating systems.	None required.
Auxiliary Spaces		
Internal combustion engines or gas turbine	40–B	Outside the space containing engines or turbines in the vicinity of the exit.
Electric emergency motors or generators	40–B:C	1 outside the space containing motors or generators in the vicinity of the exit.
Steam driven auxiliary machinery	None required.
Trunks to machinery spaces	None required.
Fuel tanks	None required.
Miscellaneous Areas		
Helicopter landing decks	160–B	1 at each access route.
Helicopter fueling facilities	160–B	1 at each fuel transfer facility. See note 2.
Drill floor	40–B:C	2 required.
Cranes with internal combustion engines	40–B:C	1 required.
Spare Units		
	2–A	10 percent of the total required rounded up.
	40–B:C	10 percent of the total required rounded up.

¹ Not required where a fixed gas extinguishing system is installed.

² Not required where a fixed foam system is installed in accordance with § 108.489 of this subpart.

[USCG–2012–0196, 81 FR 48266, July 22, 2016]

§ 108.496 Semi-portable fire extinguishers.

(a) The frame or support of each semi-portable fire extinguisher required by Table 108.495(a), except a wheeled semi-portable extinguisher provided for a helicopter landing deck, must be welded or otherwise permanently attached to a bulkhead or deck.

(b) If the following semi-portable fire extinguishers have wheels, they must be securely stowed when not in use to prevent them from rolling out of control under heavy sea conditions:

(1) Each extinguisher required for a helicopter landing deck.

(2) Each extinguisher that is not required by Table 108.495(a).

(c) Semi-portable extinguishers must be fitted with suitable hoses and nozzles, or other practicable means, so that all areas of the space can be protected.

[CGD 77–039, 44 FR 34133, June 14, 1979, as amended by USCG–2012–0196, 81 FR 48267, July 22, 2016]

MISCELLANEOUS FIREFIGHTING EQUIPMENT

§ 108.497 Fireman's outfits.

Each unit must have at least 2 fireman's outfits. Each fireman's outfit on a unit must consist of—

(a) A pressure-demand, open-circuit, self-contained breathing apparatus, approved by the Mine Safety and Health Administration (MSHA) and by the National Institute for Occupational Safety and Health (NIOSH) and having at a minimum a 30-minute air supply, a full facepiece, and a spare charge; but a self-contained compressed-air breathing apparatus previously approved by MSHA and NIOSH under part 160, subpart 160.011, of this chapter may continue in use as required equipment if it was part of the vessel's equipment on November 23, 1992, and as long as it is maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection;

(b) A Type II or Type III flashlight constructed and marked in accordance with ASTM F 1014 (incorporated by reference, see § 108.101).

(c) An oxygen and explosive meter with the Underwriter's Laboratories, Inc. label or the Factory Mutual label;

(d) A lifeline that—